



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo No.: FSR/IND/WB/FES/20182019/48775

Date : 13-07-2024

From :
Divisional Fire Officer
North 24 Parganas Division,
West Bengal Fire & Emergency Services

To :
KHALSA MODEL SENIOR SECONDARY SCHOOL
135, B.T.ROAD (NEAR DUNLOP BRIDGE) P.O-BARANAGAR, P.S-BARANAGAR, DIST-NORTH 24 PGS, PIN-700108

Sub : Renewal of Fire Safety certificate of existing G+3 storied school building under group of Institutional occupancy in the name and style of KHALSA MODEL SENIOR SECONDARY SCHOOL at 135, B.T.ROAD (NEAR DUNLOP BRIDGE), P.O-BARANAGAR, P.S-BARANAGAR, DIST-NORTH 24 PGS, PIN-700108

This is in reference to your AIN 211912406300001005 dated 20-Jun-2024 regarding Renewal of Fire Safety certificate of existing G+3 storied school building under group of Institutional occupancy in the name and style of KHALSA MODEL SENIOR SECONDARY SCHOOL at 135, B.T.ROAD (NEAR DUNLOP BRIDGE), P.O-BARANAGAR, P.S-BARANAGAR, DIST-NORTH 24 PGS, PIN-700108 .

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300001005

2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable of the Building.
6. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
7. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
8. Transformer and Switch Gear room shall be protected with automatic CO2 or D.C.P. Fire extinction confirming I.S. Specification.
9. A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
10. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
11. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12. Periodical flashing of water in the Hydrants and Sprinkler Pipe line shall be made to maintain the efficiency working performance of above mention system.
13. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
14. Another stair int he dead end side will be provided for safe evacuation purpose.

This certificate is valid for 3 years from the date of issue and renewable after three years to be obtained from the **Director General, West Bengal Fire & Emergency Services** for performance of all the life & Fire Safety arrangements and installations of the building failing which this shall be revoked automatically.

KHALSA MODEL SR. SEC. SCHOOL

[Handwritten Signature]

General secretary

Valid Upto : 12-Jul-2027



[Handwritten Signature]
 KHALSA MODEL SENIOR SECONDARY SCHOOL
 School No.-15852. Affiliation No.-2430010
 135, B. T. Road, Dunlop Bridge, Kolkata-700108

Signature valid

Digitally Signed.
 Name: SARKAR BAG
 Date: 13-Jul-2022:01:18
 Reason: D-Sign
 Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300001005